

Spring-return damper actuator, 5 Nm

SR5

Description

Damper actuator serie SR5 to operate and position air dampers in HVAC systems.

- For air dampers up to approx. 1 m²
- Nominal voltage 24 Vac/dc and 230 Vac
- Control: 2-point, on-off and proportional
- Characteristics: universal spindle clamp fo easy direct mounting, anti-rotation bracket provided for stability, selectable direction of rotation, adjustable angle of rotation, 1 m cable connection.




Technical features

Actuator model		SR5A	SR5AM	SR5B
Damper area	m ²		0,5	
Nominal torque	Nm		5	
Power supply	V	24 AC/DC	24 AC/DC	100...240 AC
Frequency	Hz		50/60	
Power consumption				
- in operation	W	5.0	5.0	6.0
- at rest	W		2.5	
- for wire sizing	VA		7.0	
Running time for motor	s	<70	<120	<70
Running time for spring	s		<20 (spring reset)	
Sound power level	db (A)		< 45	
Control signal		2 point, on-off	0(2)...10 VDC / 0(4)...20 mA	2 point, on-off
Auxiliary switch rating			3 (1.5) A, AC 250 V	
Life Cycle	cycles		70.000	
Rotation angle				
- operating			90° (95° mechanical)	
- limitation			5-85° (steps of 5°)	
Protection class		III	III	II
Protection degree			IP54	
Working range °C			-20...+50° C	
Working range RH			5...95% RH, non-condensating	
Storage temperature			-40...+70° C	
Manual override		by means of hand crank and locking switch		
Maintenance		free		
Shaft length	mm	> 90		
Shaft diameter	mm	○ 10...16 □ 7...11		
Weight	g	1800	1800	1900
Standards		CE-conformity, RoHs		
Option		suffix S for models with 2 SPDT auxiliary switches		




Electrical wirings


Wiring diagram On/Off



Wiring diagram proportional





Auxiliary switches



Settings

Limitation of rotation angle from 5° to 85°



For 5° to 45° (diagram 1)

1. Loosen screw of the mechanical limiter plate.
2. Move the limiter plate to the appropriate position.
3. Tighten the screw.

For 45° to 85° (diagram 2)

1. Release the secure ring of the adapter.
2. Remove the adapter and turn negative 45° as shown.
3. Insert adapter and secure the adapter ring.
4. Loosen screw of the mechanical limiter plate.
5. Move the limiter plate to the appropriate position.
6. Tighten the screw.

Manual override: By using the hand crank the damper can be actuated manually and engaged with the locking switch at any position. Unlocking is carried out manually or automatically by applying the operating voltage.

Dimensions (mm)

